



# PRODUCT PERFORMANCE REPORT

Document ID 1531820037

Issued on July 17th, 2018

**PROJECT IDENTIFICATION** - This product performance report is delivered for:

Name -  
 Company **Alklima bv**  
 Project reference **Intern**  
 Project location **Netherlands**

**PRODUCT IDENTIFICATION**

Certification Diploma N° **17.02.211**  
 Brand **MITSUBISHI ELECTRIC**  
 Range **S-Series**  
 Product type **European HP / Heat Pump / Variable Refrigerant Flow / Air cooled / Reverse cycle**  
 Product reference **PUMY-P125YKM3**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
<b>Acoustics</b>		
LwO env	73.0	dB(A)
<b>Cooling</b>		
Pc out	14.0	kW
Pdesignc	14.0	kW
Pec out	3.46	kW
EERout	4.05	
<b>General - Product</b>		
IU Range Names	PEFY-P*VMA3	
Main Power Supply	380V-415V,3,50Hz	
Mounting	Ducted	
Refrigerant	R410A	
<b>Heating</b>		
Ph out	16.0	kW
Peh out	3.74	kW
COPout	4.28	