



PRODUCT PERFORMANCE REPORT

Document ID 1531820154

Issued on July 17th, 2018

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name -
 Company **Alklima bv**
 Project reference **Intern**
 Project location **Netherlands**

PRODUCT IDENTIFICATION

Certification Diploma N° **17.02.211**
 Brand **MITSUBISHI ELECTRIC**
 Range **S-Series**
 Product type **European HP / Heat Pump / Variable Refrigerant Flow / Air cooled / Reverse cycle**
 Product reference **PUMY-P140YKM3**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

| FEATURE | VALUE | UNIT |
|--------------------------|------------------|-------|
| Acoustics | | |
| LwO env | 74.0 | dB(A) |
| Cooling | | |
| Pc out | 15.5 | kW |
| Pdesignc | 15.5 | kW |
| Pec out | 4.52 | kW |
| EERout | 3.43 | |
| General - Product | | |
| IU Range Names | PEFY-P*VMA3 | |
| Main Power Supply | 380V-415V,3,50Hz | |
| Mounting | Ducted | |
| Refrigerant | R410A | |
| Heating | | |
| Ph out | 18.0 | kW |
| Peh out | 4.47 | kW |
| COPout | 4.03 | |