



PRODUCT PERFORMANCE REPORT

Document ID 1531820265

Issued on July 17th, 2018

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name -
Company **Alklima bv**
Project reference **Intern**
Project location **Netherlands**

PRODUCT IDENTIFICATION

Certification Diploma N° **17.02.211**
Brand **MITSUBISHI ELECTRIC**
Range **S-Series**
Product type **European HP / Heat Pump / Variable Refrigerant Flow / Air cooled / Reverse cycle**
Product reference **PUMY-P200YKM1**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustics		
LwO env	80.0	dB(A)
Cooling		
Pc out	22.4	kW
Pdesignc	22.4	kW
Pec out	6.22	kW
EERout	3.6	
General - Product		
IU Range Names	PEFY-P*VMA3	
Main Power Supply	380V-415V,3,50Hz	
Mounting	Ducted	
Refrigerant	R410A	
Heating		
Ph out	24.0	kW
Peh out	5.76	kW
COPout	4.17	