



PRODUCT PERFORMANCE RATING

Document ID 081120200952-13870832

Issued on 11 August 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 15.10.006

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

Product	Variable refrigerant flow / Débit de réfrigérant variable (VRF)
Product type	VRF / Air cooled/ Reversible
Brand	MITSUBISHI ELECTRIC
Range	S-Series
Product référence	PUMY-P200YKM2

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
pumy	alklima	cop	Netherlands

FEATURE	VALUE	UNIT
STANDARD COOLING/COOLING PL COND A		
Pc out	22.40	kW
Pec out	6.22	kW
EERout	3.60	



PRODUCT PERFORMANCE RATING

Document ID 081120200952-13870832

Issued on 11 August 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 15.10.006

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING		
Ph out	25.00	kW
Peh out	6.00	kW
COPout	4.17	

FEATURE	VALUE	UNIT
ACOUSTICS		
LwO env	75.00	dB(A)

FEATURE	VALUE	UNIT
ACOUSTICS IN HEATING		
LwO env in heating	80.00	dB(A)

FEATURE	VALUE	UNIT
SEASONALCOOLING		
SEER	5.45	
η_{sc}	215.00	%



PRODUCT PERFORMANCE RATING

Document ID 081120200952-13870832

Issued on 11 August 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 15.10.006

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
COOLING PL COND B		
PcB	16.51	kW
EERB	5.50	

FEATURE	VALUE	UNIT
COOLING PL COND C		
PcC	10.61	kW
EERC	7.68	

FEATURE	VALUE	UNIT
COOLING PL COND D		
PcD	8.60	kW
EERD	14.33	



PRODUCT PERFORMANCE RATING

Document ID 081120200952-13870832

Issued on 11 August 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 15.10.006

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
SEASONAL HEATING AVERAGE		
P _{designh}	16.00	kW
SCOP	4.21	
η _{sh}	165.40	%

FEATURE	VALUE	UNIT
HEATING PL COND A		
PhA	14.15	kW
COPA	2.89	

FEATURE	VALUE	UNIT
HEATING PL COND B		
PhB	8.62	kW
COPB	4.42	



PRODUCT PERFORMANCE RATING

Document ID 081120200952-13870832

Issued on 11 August 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 15.10.006

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING PL COND C		
PhC	6.50	kW
COPC	5.28	

FEATURE	VALUE	UNIT
HEATING PL COND D		
PhD	6.60	kW
COPD	5.23	

FEATURE	VALUE	UNIT
T BIVALENT		
Tbiv	-10.00	°C
PhTbiv	16.00	kW
COPTbiv	2.31	

FEATURE	VALUE	UNIT
PSBC		
Psbc	65.00	W



PRODUCT PERFORMANCE RATING

Document ID 081120200952-13870832

Issued on 11 August 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 15.10.006

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
PSBH		
Psbh	65.00	W

FEATURE	VALUE	UNIT
GENERAL - PRODUCT		
Mounting	Ducted	
Cassette Type		
IU Names	2xPEFY-P40VMA3-E 2xPEFY-P63VMA3-E	
IU Range Names	PEFY-P*VMA3	
Main Power Supply	400-3-50	
Refrigerant	R410A	
Capacity Control	Variable	